

EXPRESS TERMS

ITEM 19-1

CHAPTER 1 - Administration

Model Code Adoption/Repeal: DSA-SS adopts only those sections listed below.

101.1 Title

101.1.1 [For DSA-SS] This document shall be known as the "California Plumbing Code." The provisions contained in the California Plumbing Code of the (compiled) California Building Standards Code as defined in Section 18910, Health and Safety Code, may be cited as such and are referred to hereafter as "these regulations", "these plumbing standards" or "this code."

101.2 Purpose

101.2.2 [For DSA-SS] California Purpose. To provide minimum standards to safeguard life or limb, health, property and public welfare, and protect against hazards that may arise from the use of plumbing piping and systems by regulating and controlling the design, construction, installation, quality of materials, location and operation of plumbing piping systems within the State of California.

101.4 Scope

101.4.0 [For DSA-SS] Application. The provisions of this code shall apply to the construction, alteration, moving, demolition, repair and use of all plumbing, gas, or drainage piping and systems or water heating or treating equipment in or on any building or structure or outdoors on any premise or property.

101.4.1.4.2 [For DSA-SS] Conflicts Between Codes. When the requirements of this code conflict with the requirements of the California Mechanical Code, Title 24, Part 4, the California Mechanical Code shall prevail.

101.4.4 [For DSA-SS] Effective Date. One hundred and eighty days after the date of publication, or as otherwise noted herein.

101.4.4.1 [For DSA-SS] The applicable subsection of Health and Safety Code Section 18938 is repeated here for clarity and reads as follows:

...

101.4.4.2 [For DSA-SS] the provisions of the model code which are adopted in this code are applicable to all occupancy groups and uses regulated by this code. The amendments to the model code are applicable only to those occupancies or uses which the state agency adopting the amendments is authorized to regulate as listed in Section 101.11.

101.6 [For DSA-SS] Non-Building Regulations. Requirements contained in the U.P.C. or in any other reference standard, code, or document which are not building standards as defined in Section 18909, Health and Safety Code, shall not be construed as part of the provisions of this code.

101.7 [For DSA-SS] Order of Precedence. Where, in any specific case, different sections of this code specify different materials, methods of construction or other requirements, the most restrictive shall govern. When there is a conflict between a general and a specific requirement, the specific requirement shall apply.

101.8 [For DSA-SS] Format. This part fundamentally adopts the U.P.C. by reference on a chapter-by-chapter basis. Such adoption is reflected in the adoption tables of each chapter of this part. When the adoption table of a chapter of this part makes no reference to a specific chapter of the U.P.C., such chapter is not adopted as a portion of this code.

101.9 Validity [For DSA-SS] If any chapter section, subsection, sentence, clause or phrase of this code is for any reason held to be unconstitutional, contrary to statute, exceeding the authority of the State as stipulated by statutes, or otherwise inoperative, such decision shall not affect the validity of the remaining portion of this code.

101.10 Standard Reference Documents

101.10.1 [For DSA-SS] The codes, standards and publications adopted and set forth in this code, including other codes, standards and publications referred to therein are, by title and date of publication, hereby adopted as standard reference documents of this code.

101.10.2 [For DSA-SS] When this code does not specifically cover any subject relating to building design and construction, recognized fire-prevention engineering practices shall be employed. The National Fire Codes and Fire Protection Handbook of the National Fire Protection Association may be used as authoritative guides in determining recognized fire-prevention engineering practices.

101.11 [For DSA-SS] Application-Vesting Authority

101.11.10 [For DSA - SS] Division of the State Architect - Structural Safety

Application - Public elementary and secondary schools, community college buildings, and state-owned or state-leased essential services buildings.

Enforcing Agency - DSA - SS

Authority Cited - Education Code § 17310 and 81142, and H&S Code §16022.

Reference - Education Code §§ 17280 through 17317, and 81130 through 81147, and H&S Code §§16000 through 16023.

The Division of the State Architect has been delegated the responsibility and authority by the Department of General Services to review and approve the design and observe the construction of public school buildings, and state-owned or state-leased essential services buildings.

The applicable building standards are as follows:

1. Administrative Regulations.

- 1.1 School Buildings; Sections 4-301 through 4-355, Group 1, Chapter 4, Part 1, Title 24, California Code of Regulations.
- 1.2 State-owned or State-leased Essential Services Buildings; Sections 4-201 through 4-249, Chapter 4, Part 1, Title 24, California Code of Regulations.

2. Technical Regulations.

Various model codes adopted by reference into the California Building Standards Code, Title 24, Parts 2, 3, 4, 5, 6, 7, 12, California Code of Regulations, for school buildings, and state-owned or state-leased essential services buildings.

The Division of the State Architect, in the performance of its duties, coordinates with other state offices as follows:

- 2.1 California Building Standards Commission
- 2.2 Office of Statewide Health Planning and Development
- 2.3 Office of the State Fire Marshal
- 2.4 Real Estate Services Division
- 2.5 Office of Public School Construction

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

ITEM 19-1 – Committee Recommendations

A AA D FS

* * *
(END OF ITEM)

ITEM 19-2

CHAPTER 2 - Definitions

Model Code Adoption/Repeal: Repeal entire 2000 edition UPC Chapter 2 (Definitions), and adopt entire 2003 edition UPC Chapter 2 as amended (amended sections listed below).

203.0 -A-

AUTHORITY HAVING JURISDICTION. The organization, office, or individual responsible for enforcing the requirements of a code or standard, or for approving equipment, materials, installations, or procedures. The Authority Having Jurisdiction shall be a federal, state, local, or other regional department or an individual such as a plumbing official, mechanical official, labor department official, health department official, building official, or others having statutory authority. In the absence of a statutory authority, the authority having

jurisdiction may be some other responsible party. This definition shall include the authority having jurisdiction's duly authorized representative. **[For DSA-SS]** See enforcing agency.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

205. -C-

California Building Code [For DSA-SS] *The most recent edition of Title 24, Part 2, California Code of Regulations.*

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

207.0 -E-

Enforcing Agency [For DSA - SS] *is the designated department or agency as specified in statutes and regulations to enforce the specific building standards promulgated or adopted by the specified state agency.*

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

216.0 -N-

Noncarriage Toilet Facility [For DSA - SS] *a toilet facility not connected to a sewer.*

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

218.0 -P-

Personal Service Room [For DSA - SS] *A room which is not directly connected with the production or service function performed by the establishment. Such rooms may include, but are not limited to, first aid or medical rooms, toilet rooms, change rooms, wash rooms, shower rooms, kitchens and lunch rooms.*

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

221.0 -S-

~~**State Building Codes [For DSA - SS]** *The most recent edition of the California Code of Regulations, Title 24, Part 2, known as the California Building Code.*~~

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

223.0 -U-

U.P.C. [For DSA - SS] *The latest edition of the Uniform Plumbing Code published by the International Association of Plumbing and Mechanical Officials.*

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

ITEM 19-2 – Committee Recommendations

A AA D FS

* * *
(END OF ITEM)

ITEM 19-3

CHAPTER 3 - General Regulations

Model Code Adoption/Repeal: Repeal entire 2000 edition UPC Chapter 3 (General Regulations), and adopt entire 2003 edition UPC Chapter 3 as amended (amended sections listed below).

316.2.4 [For DSA-SS] Dielectric unions shall be used at all points of connection where there is a dissimilarity of metals.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

ITEM 19-3 – Committee Recommendations

A AA D FS

* * *
(END OF ITEM)

ITEM 19-4

CHAPTER 4 - Plumbing Fixtures and Fixture Fittings

Model Code Adoption/Repeal: Repeal entire 2000 edition UPC Chapter 4 (Plumbing Fixtures), and adopt entire 2003 edition UPC Chapter 4 as amended (amended sections listed below).

407.4 Drinking Fountains

407.4.1 [For DSA-SS] Drinking fountains shall be installed and so regulated that a jet of water extending at least two inches from the water orifice shall be constantly available. The orifice shall not be accessible to the mouth of the drinker not subject to immersion.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

CHAPTER 5 - Water Heaters

Model Code Adoption/Repeal: Repeal entire 2000 edition UPC Chapter 5 (Water Heaters), and adopt entire 2003 edition UMC Chapter 5 without amendment.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

ITEM 19-4 – Committee Recommendations

A AA D FS

* * *

(END OF ITEM)

ITEM 19-5

CHAPTER 6 - Water Supply and Distribution

Model Code Adoption/Repeal: Repeal entire 2000 edition UPC Chapter 6 (Water Supply and Distribution), and adopt entire 2003 edition UPC Chapter 6 as amended (amended sections listed below).

604.0 Materials

604.1 Water distribution pipe, building supply water pipe, and fittings shall be of brass, copper, cast iron, CPVC, galvanized malleable iron, galvanized wrought iron, galvanized steel, PEX, or other approved materials. Asbestos-cement, PE, PVC, PEX-AL-PEX, or PE-AL-PE water pipe manufactured to recognized standards may be used for cold water building supply distribution systems outside a building. PEX-AL-PEX water pipe, tubing, and fittings manufactured to recognized standards may be used for hot and cold water distribution systems within a building. PE-AL-PE water pipe and fittings may be used for cold water distribution systems within a building. All materials used in the water supply system, except valves and similar devices, shall be of a like material, except where otherwise approved by the Authority having Jurisdiction.

[For DSA-SS] Exception: Use of PEX or PEX-AL-PEX piping is not adopted for applications under the authority of the Division of the State Architect-Structural Safety.

604.11 PEX. [Not adopted by DSA-SS] Cross-linked polyethylene (PEX) tubing shall be marked with the appropriate standard designation(s) listed in Table 14-1 for which the tubing has been approved. PEX tubing shall be installed in compliance with the provisions of this section.

604.11.1 PEX Fittings. [Not adopted by DSA-SS] Metal insert fittings, metal compression fittings, and cold expansion fittings used with PEX tubing shall be manufactured to and marked in accordance with the standards for the fittings in Table 14-1.

604.11.2 Water Heater Connections. [Not adopted by DSA-SS] PEX tubing shall not be installed within the first eighteen (18) inches (457mm) of the piping connected to a water heater.

604.13 PEX-AL-PEX and PE-AL-PE. Crosslinked Polyethylene-Aluminum-Crosslinked Polyethylene (PEX-AL-PEX) and Polyethylene-Aluminum-Polyethylene (PE-AL-PE) composite pipe shall be marked with the appropriate standard designations listed in Table 14-1 for which the pipe has been listed or approved. PEX-AL-PEX and PE-AL-PE shall be installed in compliance with the provisions of this section.

[For DSA-SS] Exception: Use of PEX-AL-PEX piping is not adopted for applications under the authority of the Division of the State Architect-Structural Safety.

604.13.1 PEX-AL-PEX and PE-AL-PE. Fittings used with PEX-AL-PEX and PE-AL-PE piping shall be manufactured to and marked in accordance with the standard for the fittings in Table 14-1.

[For DSA-SS] Exception: Use of PEX-AL-PEX piping is not adopted for applications under the authority of the Division of the State Architect-Structural Safety.

604.13.2 Water Heater Connections. PEX-AL-PEX or PE-AL-PE tubing shall not be installed within the first eighteen inches of piping connected to a water heater.

[For DSA-SS] Exception: Use of PEX-AL-PEX piping is not adopted for applications under the authority of the Division of the State Architect-Structural Safety.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

606.2.4 PVC Pipe

606.2.4.1 [For DSA-SS] Joints in PVC pipe shall be made as provided in Section 316.1.6, U.P.C.

609.11 [For DSA-SS] Refer to Title 24, Part 2 of the California Building Code for seismic anchorage and bracing requirements and accommodations for building displacements.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

ITEM 19-5 – Committee Recommendations

A AA D FS

* * *
(END OF ITEM)

ITEM 19-6

CHAPTER 7 - Sanitary Drainage

Model Code Adoption/Repeal: Repeal entire 2000 edition UPC Chapter 7 (Sanitary Drainage), and adopt entire 2003 edition UPC Chapter 7 as amended (amended sections listed below).

701.1.2.1 [For DSA-SS] ABS and PVC installations are limited to residential construction not more than two stories in height and to relocatable public school buildings.

705.1.1.1 Caulked Joints [For DSA-SS] All joints for liquid material are to be reamed to full size and cleaned of all loose materials.

705.2.5 [For DSA-SS] Joints in ABS and PVC pipe shall be made as provided in Section 316.0, U.P.C.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

ITEM 19-6 – Committee Recommendations

A AA D FS

* * *
(END OF ITEM)

ITEM 19-7

CHAPTER 8 - Indirect Wastes

Model Code Adoption/Repeal: Repeal entire 2000 edition UPC Chapter 8 (Indirect Wastes), and adopt entire 2003 edition UPC Chapter 8 as amended (amended sections listed below).

811.2.1 [For DSA-SS] ABS or PVC installations are permitted for lines carrying acid wastes in public school building laboratories.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

CHAPTER 9 - Vents

Model Code Adoption/Repeal: Repeal entire 2000 edition UPC Chapter 9 (Vents), and adopt entire 2003 edition UPC Chapter 9 without amendment.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

CHAPTER 10 - Traps and Interceptors

Model Code Adoption/Repeal: Repeal entire 2000 edition UPC Chapter 10 (Traps and Interceptors), and adopt entire 2003 edition UPC Chapter 10 without amendment.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

CHAPTER 11 - Storm Drainage

Model Code Adoption/Repeal: Repeal entire 2000 edition UPC Chapter 11 (Storm Drainage), and adopt entire 2000 edition UPC Chapter 11 without amendment.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

ITEM 19-7 – Committee Recommendations

A AA D FS

* * *

(END OF ITEM)

ITEM 19-8

CHAPTER 12 - Fuel Piping

Model Code Adoption/Repeal: Repeal entire 2000 edition UPC Chapter 12 (Fuel Piping), and adopt entire 2003 edition UPC Chapter 12 as amended (amended sections listed below).

~~4202.2.1~~ 1203.10 [For DSA - SS] Earthquake- actuated Gas Shutoff Valve. A valve for installation in a gas piping system and designed to automatically shut off the gas at the location of the valve in the event of a seismic disturbance.

~~4244.24~~ 1211.17 [For DSA-SS] Earthquake-actuated Gas Shutoff Valves. Earthquake-actuated gas shutoff valves, certified by the state architect as conforming to California Referenced Standard 12-16-1, shall be provided for buildings when such installation is required by local ordinance. Earthquake-actuated gas shutoff valves which have not been certified by the state architect shall be prohibited in buildings open to the public under mandatory installation by local ordinance.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

ITEM 19-8 – Committee Recommendations

A AA D FS

* * *

(END OF ITEM)

ITEM 19-9

CHAPTER 13 - Health Care Facilities and Medical Gas and Vacuum Systems

Model Code Adoption/Repeal: Do not adopt 2003 edition UPC Chapter 13.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

CHAPTER 14 - Mandatory Referenced Standards

Model Code Adoption/Repeal: Repeal entire 2000 edition UPC Chapter 12 (Mandatory Referenced Standards), and adopt entire 2003 edition UPC Chapter 14 without amendment.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

CHAPTER 15 - Firestop Protection

Model Code Adoption/Repeal: Do not adopt 2003 edition UPC Chapter 15.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

APPENDIX A - Recommended Rules for Sizing the Water Supply System

Model Code Adoption/Repeal: Repeal entire 2000 edition UPC and adopt entire 2003 edition UMC Appendix A without amendment.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

APPENDIX B - Explanatory Notes on Combination Waste and Vent Systems

Model Code Adoption/Repeal: Repeal entire 2000 edition UPC Appendix B (Explanatory Notes on Combination Waste and Vent Systems), and adopt entire 2003 edition UPC Appendix B without amendment.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

APPENDIX C - Deleted

Model Code Adoption/Repeal: Do not adopt 2003 edition UPC Appendix C.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

APPENDIX D - Sizing Stormwater Drainage Systems

Model Adoption/Repeal: Repeal entire 2000 edition UPC Appendix D (sizing Stormwater Drainage Systems), and adopt 2003 edition UPC as amended (see amended sections below).

D1 Roof Drainage

The rainfall rates in Table D-1 should be used for design unless higher values are established locally.

a.1 [For DSA-SS] ABS and PVC installations are limited to residential buildings and relocatable public school buildings, not more than two stories in height.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

APPENDIX E - Manufactured / Mobile Home Parks and Recreational Vehicle Parks

Model Code Adoption/Repeal: Do not adopt 2003 edition UPC Appendix E.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

APPENDIX F - Reserved

Model Code Adoption/Repeal: Do not adopt 2003 edition UPC Appendix F.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

APPENDIX G - Graywater Systems for Single Family Dwellings

Model Adoption/Repeal: Do not adopt 2003 edition UPC Appendix G.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

APPENDIX H - Recommended Procedures for Design, Construction and Installation of Commercial Kitchen Grease Interceptors

Model Code Adoption/Repeal: Repeal entire 2000 edition UPC Appendix H (Recommended Procedures for Design, Construction and Installation of Commercial Kitchen Grease Interceptors), and adopt entire 2003 edition UPC Appendix H without amendment.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

APPENDIX I - Installation Standards

Model Code Adoption/Repeal: Do not adopt 2003 edition UPC Appendix I.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

APPENDIX K - Private Sewage Disposal Systems

Model Code Adoption/Repeal: Repeal entire 2000 edition UPC Appendix K (Private Sewage Disposal Systems), and adopt entire 2003 edition UPC Appendix K without amendment.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

APPENDIX J - Alternate Plumbing Systems

Model Code Adoption/Repeal: Do not adopt 2003 edition UPC Appendix J.

Notation

Authority: Education Code Sections 17310, 81142; Health & Safety Code Section 16022

Reference(s): Education Code Sections 17280 - 17317, and 811130 - 81149; Health & Safety Code Sections 16000 - 16023

ITEM 19-9 – Committee Recommendations

A AA D FS

* * *

(END OF ITEM)

INITIAL STATEMENT OF REASONS

The specific purpose and rationale of this proposal to adopt the 2003 edition UPC is to conform with the intent of the following statutes contained within State Building Standards Law:

- Health & Safety Code Section 18928, which mandates the adoption of the most recent edition of model codes within one year of publication.
- Health & Safety Code Section 18941.5, which prescribes that standards contained within the Uniform Plumbing Code (by the International Association of Mechanical and Plumbing Officials) shall apply to all occupancies throughout the state.

STATEMENT OF SPECIFIC PURPOSE AND RATIONALE FOR PROPOSED CHANGES

(Existing Amendments with Proposed Changes or Repeal)

CHAPTER 1

Section 101.8 - Existing California amendment Sec. 101.8 (Format) to the CPC is corrected to meet intent of the provision, as stated in the CA Mechanical Code Section 103.1.7.

CHAPTER 2

Section 203.0 - Add current (2001 CPC) amendment language referencing the state agency term "enforcing agency" to the definition of *Authority Having Jurisdiction*. Current amendment is applicable to 2000 ed. UPC definition for *Administrative Authority*, which has been replaced with the term "*Authority Having Jurisdiction*" in the 2003 edition UPC.

Section 221.0 - Repeal definition of "State Building Codes", as this term is only promulgated by DSA-SS and is no longer used within the code.

CHAPTER 6

Sections 604.1, 604.11, 604.11.1, 604.11.2, 604.13, 604.13.1, 604.13.2 - Continue current amendment by DSA-SS, and amend to include the newly codified material PEX-AL-PEX (exception noting that PEX is not adopted for applications under the authority of DSA-SS), pending resolution of the State Attorney General's filing on April 1, 2003 of the Notice of Appeal to the court's judgment and writ of mandate issued February 13, 2003 (Case No. BS 076413, Plastic Pipe and Fittings Association vs. State of California).

CHAPTER 12

Section 1203.10 - Editorial change required; renumber from 1202.2.1 to 1203.10 due to model code format change.

Section 1211.17 - Editorial change required; renumber from 1211.21 to 1211.17 due to model code format change.

TECHNICAL, THEORETICAL, AND EMPIRICAL STUDY, REPORT, OR SIMILAR DOCUMENTS

No technical, theoretical or empirical studies or reports were used, as proposed changes are editorial.

CONSIDERATION OF REASONABLE ALTERNATIVES

Proposed action consists of editorial changes only, so no alternatives were considered.

REASONABLE ALTERNATIVES THE AGENCY HAS IDENTIFIED THAT WOULD LESSEN ANY ADVERSE IMPACT ON SMALL BUSINESS

The Division of the State Architect has not identified any alternatives to these proposed editorial changes, and no adverse impact to small business due to these proposed editorial changes is expected.

FACTS, EVIDENCE, DOCUMENTS, TESTIMONY, OR OTHER EVIDENCE OF NO SIGNIFICANT ADVERSE ECONOMIC IMPACT ON BUSINESS.

The Division of the State Architect does not expect these proposed editorial changes to pose any adverse economic impact on business.

DUPLICATION OR CONFLICTS WITH FEDERAL REGULATIONS

The Regulations do not duplicate or conflict with federal regulations.

.